

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 60146335

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

Date of Issue

0001--27145437 001

22.01.2020

(day/mo/yr)

Genehmigungsinhaber *License Holder*

KASTRO KABLO SAN. VE TİC. A.Ş.
TERAZİDERE MAH. GÜNEŞTEL SOK. NO: 5
34035 BAYRAMPAŞA İSTANBUL
Türkiye

Fertigungsstätte *Manufacturing Plant*

KASTRO KABLO SAN. VE TİC. A.Ş.
OSMANGAZI MAH. 2647. SOKAK NO. 27 B1
KIRAÇ ESENYURT
34522 İSTANBUL
Türkiye

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111220638

Geprüft nach *Tested acc. to*
DIN VDE 0815:1985+A1

**Zertifiziertes Produkt (Geräteidentifikation)
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit
*License Fee - Unit***

Cable (Indoor installation fire alarm cables)

Code designation: JE-H(St)H..Bd
1x2x0,8 mm to 4x2x0,8mm
Conductor diameter: 0,8mm acc. to DIN VDE 0815
number of pairs: 1,2,3,4
Trademark: KASTRO KABLO
Rated voltage: Max.225V AC
Temperature range : -30°C...+70°C
Test voltage: 500 V (core-core),
2000 V (core-screen)

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Sahure Orak