

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 60146336

Blatt Sheet
0001

Ihr Zeichen Client Reference	Unser Zeichen Our Reference	Ausstellungsdatum Date of Issue
	0001--27145439 001	22.01.2020 (day/mo/yr)

Genehmigungsinhaber License Holder

KASTRO KABLO SAN. VE TİC. A.Ş.
TERAZİDERE MAH. GÜNEŞTEL SOK. NO: 5
34035 BAYRAMPAŞA İSTANBUL
Türkiye

Fertigungsstätte Manufacturing Plant

KASTRO KABLO SAN. VE TİC. A.Ş.
OSMANGAZI MAH. 2647. SOKAK NO. 27 B1
KIRAÇ ESENYURT
34522 İSTANBUL
Türkiye

Prüfzeichen Test Mark



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111220639

Geprüft nach Tested acc. to

DIN VDE 0815:1985+A1
DIN VDE 0812/11.88

Zertifiziertes Produkt (Geräteidentifikation) Certified Product (Product Identification)

Lizenzentgelte - Einheit License Fee - Unit

Cable (Fire resistant braid screened signal and control cable)

Code designation:	LIHCH FE 180 PH 120	5
Cross-sectional area acc. to IEC 60228:2004 Table 3)		
Cross-sectional area:	0,75mm ² , 1,00mm ² , 1,50mm ² , 2,50mm ²	
Number of core:	2,3,4	
Trademark:	KASTRO KABLO	
Rated voltage:	Max.500 V AC	
Temperature range for fixed installation:	-30°C...+70°C	
Temperature range for flexible installation:	-5°C...+50°C	
Test voltage:	1200 V	
Resistance to fire (acc. to EN 50200):	PH 180	
Circuit integrity (acc. to IEC 60331-23):	FE 180	

5

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Sahure Oralap