

Declaration of Performance

DoP Number: **KST-205-115-44**

1. *Identification of the product-type :*

Signal and Control Cables

2. *Descripton of product type :*

LIYCY-TP

3. *Intended uses :*

Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

4. *Contact address :*

KASTRO KABLO SAN.TİC. A.Ş
Çerkezköy O.S.B. Karaağaç Mah. Fatih Bulvarı Atatürk Cad. No:30/J Kapaklı / Tekirdağ
Tel: +90 282 758 23 24
e-mail: info@kastrokablo.com

5. *System or systems of assesment and verification of constancy of performance of the construction product:*

System 3

6. *Notified product certification body no :*

1783

7. *Declared performance :*

<i>Essential Characteristics</i>	<i>Performance</i>	<i>Harmonized Technical Specification</i>
<i>Reaction to fire</i>	Eca	EN 50575:2014+A1:2016
<i>Dangerous Substances</i>	None	

8. *The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 7. This declaration of performance is issue under the sole responsibility of the manufacturer identified in point 4.*

Signed for on behalf of the manufacturer by;
General Manager
31/08/2018



KASTRO KABLO SAN.TİC. A.Ş

Çerkezköy O.S.B Karaağaç Mah.Fatih Bulvarı No:30 /J Kapaklı / Tekirdağ – TÜRKİYE
T : 0.(282) 758 23 24 (pbx) info@kastrokablo.com - satis@kastrokablo.com - export@kastrokablo.com
www.kastrokablo.com