

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
R 60146296

Blatt *Sheet*  
0002

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

*Date of Issue*

0001-I.Ü.-27145438 002 06.10.2021 (day/mo/yr)

**Genehmigungsinhaber *License Holder***

KASTRO KABLO SAN. VE TİC. A.Ş.  
TERAZİDERE MAH.GÜNEŞTEL SOK.  
NO:5  
34035 BAYRAMPAŞA-İSTANBUL  
Türkiye

**Fertigungsstätte *Manufacturing Plant***

KASTRO KABLO SAN. VE TİC. A.Ş.  
Çerkezköy O.S.B. Karaağaç Mah.  
Fatih Bulvarı Atatürk Cad. No:30/J  
Kapaklı-Tekirdağ  
Türkiye

**Prüfzeichen *Test Mark***



Type Approved  
Safety  
Regular Production  
Surveillance  
[www.tuv.com](http://www.tuv.com)  
ID 1111220628

**Geprüft nach *Tested acc. to***

DIN VDE 0815:1985+A1

**Zertifiziertes Produkt (Geräteidentifikation)  
*Certified Product (Product Identification)***

**Lizenzentgelte - Einheit  
*License Fee - Unit***

Cable ( Indoor installation fire alarm cables)

Code designation: JE-H(St)H..Bd FE 180 PH 120  
from 1x2x0,8mm to 2x2x0,8mm  
Conductor diameter: 0,8mm acc. to DIN VDE 0815  
number of pairs: 1,2

Trademark: KASTRO KABLO

Rated voltage: Max.225V AC

Temperature range : -30°C...+70°C

Test voltage: 500 V (core-core),  
2000 V (core-screen)

Resistance to fire (acc. to EN 50200): PH 180

Circuit integrity (acc. to IEC 60331-23): FE 180  
Modification: Manufacturer address changed.

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.  
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

<http://www.tuv.com/safety> E-mail: [markcheck@tuv.com](mailto:markcheck@tuv.com)  
Fax: +49 221 806-3935

