

**Declaration of Performance**

DoP Number: **KST-880-223-10**

1. *Identification of the product-type :*

**Instrumentation and Control Cables**

2. *Descripton of product type :*

**RE-2X(St)H-fl Pimf 5x2x1.5 mm<sup>2</sup>**

3. *Intended uses :*

**Supply of electricity in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke**

4. *Contact address :*

**KASTRO KABLO SAN.TİC. A.Ş**  
**Çerkezköy O.S.B. Karaağaç Mah. Fatih Bulvarı Atatürk Cad. No:30/J Kapaklı / Tekirdağ**  
**Tel: +90 282 758 23 24**  
**e-mail: info@kastrokablo.com**

5. *System or systems of assesment and verification of constancy of performance of the construction product:*

**System 3**

6. *Notified product certification body no :*

**1783**

7. *Declared performance :*

<i>Essential Characteristics</i>	<i>Performance</i>	<i>Harmonized Technical Specification</i>
<i>Reaction to fire</i>	<b>Dca-s2,d1,a1</b>	<b>EN 50575:2014+A1:2016</b>
<i>Dangerous Substances</i>	<b>None</b>	

8. *The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 7. This declaration of performance is issue under the sole responsibility of the manufacturer identified in point 4.*

Signed for on behalf of the manufacturer by;  
Technical Office Manager  
11/10/2025



**KASTRO KABLO SAN.TİC. A.Ş**

Çerkezköy O.S.B Karaağaç Mah.Fatih Bulvarı No:30 /J Kapaklı / Tekirdağ – TÜRKİYE  
T : 0.(282) 758 23 24 (pbx) info@kastrokablo.com - satis@kastrokablo.com - export@kastrokablo.com  
www.kastrokablo.com